

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0026:234 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *FAX (978) 731-8881

DESIGN: Model 3007-9001 fire alarm control units. Coded or noncoded, automatic, manual, local, central station, remote station, waterflow, and sprinkler supervisory service. Refer to listee's printed data sheet for additional detailed product description and operational considerations. Basic system:

3007-9001	Control Panel
3007-9805	8-Zone Expansion Module
3007-9802	Fire Module
3007-9803	Multiplex Expander Module
3007-9810	Single Phone Line Monitor
3007-9811	Relay Board

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: 1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet and installation instructions for compatible non-fire devices.

2. For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1062:113

*Rev. 05-31-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager